

11 September 2018  
C/O: LCIE CHINA Co., Ltd.  
Building 4, No. 518, Xinzhuan Road, Caohejing Songjiang High-Tech Park, Shanghai, P.R.China  
(201612)

Zhejiang Chint Electrics Co.Ltd.

Dear Sir / Madam,

**APPROVAL OF PRESCRIBED EQUIPMENT**

Enclosed is the Certificate(s) in respect to your recent application received by Energy Safe Victoria.


Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact Goran Sokoleski on telephone 92039703, or email [gsokoleski@esv.vic.gov.au](mailto:gsokoleski@esv.vic.gov.au)

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Energy Safe Victoria of any change of registered Address within 20 business days.

Yours sincerely



**DIRECTOR OF ENERGY SAFETY**

Ref: ESV180448/00

Certificate Number: ESV180448/00

# Certificate of Approval

This is to certify that the Director of Energy Safety has approved the electrical equipment described hereunder.

**Registered Declarant:** Zhejiang Chint Electrics Co.Ltd.  
No.1,Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,  
Zhejiang Province,P. R. China 325603

## Required Marking: ESV180448

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, must be clearly and indelibly marked with the required marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Energy Safe Victoria prior to the equipment being supplied or offered for supply.

Notification must be given to Energy Safe Victoria of any change to the name or address of the holder of the certificate within 20 business days.

## ARTICLE DETAILS

Electrical Equipment:	Level 3 Miniature Overcurrent Circuit-Breaker MOCB
Relevant Standards:	AS/NZS60898-1:2004
Expiry Date:	11 September 2023
Conditions of Approval:	Alternate approval marking ESV130768



Certificate Number: ESV180448/00

## Approval details

240 V~/415 V~ (1P); 415 V~ (2P,3P,4P); instantaneous trip current: B / C / D type
---

Model	NB1-63H
Rated at	Input: 240 / 415 V~, 1/2/3/4/6/10/16/20/25/32/40/50/63A, 50/60 Hz
Trade Name	CHINT, Voltex
Comments	Ics 7.5kA

Model	NB1-63
Rated at	Input: 240 / 415 V~, 1/2/3/4/6/10/16/20/25/32/40/50/63A, 50/60 Hz
Trade Name	CHINT, Voltex
Comments	Ics 6kA

